

Representative: LG Electronics Inc. EU Representative, Krijgsman 1, 1186 DM Amstelveen, The Netherlands
Manufacturer: LG Electronics Inc. Changwon 2nd factory, 84, Wanam-ro, Seongsan-gu, Changwon-si, Gyeongsangnam-do, KOREA

LG
Life's Good

ENGLISH
ITALIANO
ESPAÑOL
FRANÇAIS
DEUTSCH
ΕΛΛΗΝΙΚΆ
ČEŠTINA
NEDERLANDS
POLSKI
LIMBA ROMÂNĂ
EESTI KEEL
DANSK
ÍSLENSKA
BOSANSKI
SHQIP
SUOMI
NORSK
SVENDKA
HRVATSKI
SRPSKI
БЪЛГАРСКИ
SLOVENŠČINA
MAGYAR
SLOVENČINA
PORTUGUESE
MALTI
LATVIEŠU VALODA
LIETUVIŲ KALBA
GAEILGE
МАКЕДОНСКИ

INSTALLATION MANUAL

AIR CONDITIONER

Please read this installation manual completely before installing the product.
Installation work must be performed in accordance with the national wiring standards by authorized personnel only.
Please retain this installation manual for future reference after reading it thoroughly.

PRDSBM

P/NO : MFL67525609

ENGLISH

Outdoor Dry Contact (PRDSBM) Installation Manual

1. Check the contents of Outdoor Dry Contact(PRDSBM).




<Outdoor Dry Contact Main Body>



<Front Case>

2. Connect Outdoor Main PCB and Outdoor Dry Contact


- Connect terminals(DRY1, DRY2, GND) on the back side of the outdoor dry contact to terminals (DRY1, DRY2, GND) of outdoor as show below.



< Outdoor Main PCB >

shows field wiring

connected wiring



Push Button

- Insert wire method -



Push arrow direction.



Insert wire to connector.


<Outdoor Dry Contact Back Side >

❊ Communication line length can be maximum 300m, use communication line as thick as 1.25mm^2.

⚠ CAUTION

Pay attention to the wiring when the Push Button on the back side of Outdoor Dry Contact is pressed and the wires are pulled out.

3. Outdoor dry contact combines with switch box as shown below



Switch Box

4. Attach the front case