



# LG **THERMAV**™ Air-to-Water Heat Pump

### Alf-to- water Hea *Owner's Manual*

Models : AH Series

Dear Owner Thank you for installing LG Air-to-Water Heat Pump. Your best choice guarantees you a great performance and service to make your life comfortable & pleasant.



- Please read this owner's manual carefully and thoroughly before installing and operating your Air-to-Water Heat Pump.
- Please retain this owner's manual for future reference after reading it thoroughly.

Air-to-Water Heat Pump Owner's Manual

# **TABLE OF CONTENTS**

- A. Safety Precautions......3
- B. Product Introduction......6
- C. Owner's instruction.....8
- D. Using Thermostat......33
- E. Maintenance and Service ......37
- F. Disposal Requirements......39

## *∭* FOR YOUR RECORDS

Write the model and serial numbers here:

#### Model #

#### Serial #

You can find them on a label on the side of each unit.

#### Installer's Name

#### **Purchased Date**

Staple your receipt to this page in the event you



need it to prove date of purchase or for warranty issues.

## **READ THIS MANUAL**

Inside you will find many helpful hints on how to use and maintain your AWHP properly. Just a little preventive care on your part can save you a great deal of time and money over the life of your product.

You'll find many answers to common problems in the chart of troubleshooting tips. If you review our chart of



Troubleshooting Tips first, you may not need to call for service at all.

## PRECAUTION

- Contact the authorized service technician for repair or maintenance of this unit.
- Contact the installer for installation of this unit.
- AWHP is not intended for use by young children or invalids without supervision.
- Young children should be supervised to ensure that they do not play with AWHP.
- When the power cable is to be replaced, replacement work shall be performed by authorized personnel only using only genuine replacement parts.
- Installation work must be performed in accordance



## **Safety Precautions**

To prevent injury to the user or other people and property damage, the following instructions must be followed. ■ Incorrect operation due to ignoring instruction will cause harm or damage. The seriousness is classified by the following indications.

**WARNING** This symbol indicates the possibility of death or serious injury.

This symbol indicates the possibility of injury or damage.



#### Safety Precaution

Indoor/outdoor wiring connections must be secured tightly and the cable should be routed properly so that there is no force pulling the cable from the connection terminals.	Safely dispose off the packing materials. Like screws, nails, batteries, broken things etc after installation or service and then tear away and throw away the plastic packaging bags.	Make sure to check that the power device is not dirty, loose or broken and then Turn on the power.
• Improper or loose connections can cause heat generation or fire.	Children may play with them and cause injury.	Dirty, loose or broken power device can cause electric shock or fire.
In outdoor unit the step-up capacitor supplies high voltage electricity to the electrical components. Be sure to discharge the capacitor completely before conducting the repair work.	When installing the unit, use the installation kit provided with the product.	Be sure to use only those parts which are listed in the service parts list. Never attempt to modify the equipment.
An charged capacitor can cause electrical shock.	Otherwise the unit may fall and cause severe injury.	<ul> <li>The use of inappropriate parts can cause an electrical shock, excessive heat generation or fire.</li> </ul>
Do not use the product in a tightly closed space for a long time. Perform ventilation regularly.	Do not open the front cover or grille of the product during operation. (Do not touch the electrostatic filter, if the unit is so equipped.)	If strange sounds, smell or smoke comes from product, immediately turn the breaker off or disconnect the power supply cable.
Oxygen deficiency could occur and hence harm your health.	There is risk of physical injury, electric shock, or product failure.	There is risk of electric shock or fire.
Ventilate the product room from time to time when operating it together with a stove, or heating element etc.	Turn the main power off when cleaning or repairing the product.	Take care to ensure that nobody especially kids could step on or fall onto the outdoor unit.
Oxygen deficiency can occur and hence harm your health.	There is risk of electric shock.	<ul> <li>This could result in personal injury and product damage.</li> </ul>
Take care to ensure that power cable could not be pulled out or damaged during operation.	Do not place ANYTHING on the power cable.	When flammable gas leaks, turn off the gas and open a window for ventilation before turn the product on.
There is risk of fire or electric shock.	There is risk of fire or electric shock.	• Do not use the telephone or turn switches of


 Do not use the telephone or turn switches on or off. There is risk of explosion or fire.

ENGLISH

Two or more people must lift and transport the product.	Do not install the product where it will be exposed to sea wind (salt spray) directly.	Keep level even when installing the product.
Avoid personal injury.	• It may cause corrosion on the product.	To avoid vibration or noise.
Do not install the product where the noise or hot air from the outdoor unit could damage or disturb the neighborhoods.	Always check for gas (refrigerant) leakage after installation or repair of product.	Do not use the product for special purposes, such as preserving foods, works of art, etc. It is a consumer AWHP, not a precision refrigeration system.
It may cause a problem for your neighbors and hence dispute.	Low refrigerant levels may cause failure of product.	There is risk of damage or loss of property.
Do not block the inlet or outlet of air flow.	Use a soft cloth to clean. Do not use harsh detergents, solvents or splashing water etc.	Do not step on or put anyting on the product. (outdoor units)
It may cause product failure.	There is risk of fire, electric shock, or damage to the plastic parts of the product.	There is risk of personal injury and failure of produc
Do not insert hands or other objects through the air inlet or outlet while the product is operating.	Be cautious when unpacking and installing the product.	If the refrigerant gas leaks during the repair, do not touch the leakaing refrigerant gas.
There are sharp and moving parts that could cause personal injury.	Sharp edges could cause injury.	The refrigernat gas can cause frostbite (cold burn)
Do not tilt the unit when removing or uninstalling it.	Do not mix air or gas other than the specified refrigerant used in the system .	If the refrigerant gas leaks during the installation, ventilate the area immediately
The condensed water inside can spill .	<ul> <li>If air enters the refrigerant system, an excessively high pressure results, causing equipment damage or injury.</li> </ul>	Otherwise it can be harmfull for your health.
Dismantling the unit, treatment of the refrigerant oil and eventual parts should be done in accordance with local and national standards.	Do not expose your skin or kids or plants to the cool or hot air draft.	Use a firm stool or ladder when cleaning, maintaining or repairing the product at an height.
	This could harm to your health.	<ul> <li>Be careful and avoid personal injury.</li> </ul>

## **Product Introduction**


### Typical Installation Scene



- 1. Indoor unit
- 2. Outdoor unit
- 3. Refrigerant pipe and connecting cable
- 4. Water pipe
- 5. Ground wire to ground outdoor unit to prevent electrical shocks.

\*The shape of products can be chaged according to the model capacity and type.

### **Control Panel**




- 1. Display panel
- 2. Change temperature button
- 3. Silent mode On/Off button
- 4. Operation mode selection button
- 5. Water heating Enable/Disable button
- 6. ESC button
- 7. Direction button (Up, Down, Left, Right)
- 8. Power button

- 9. Function setting button
- 10. Temperature setting mode button
- 11. Temperature view mode button
- 12. Programming button
- 13. Set/Clear button

\* Some functions may not be operated and displayed depending on the model.

## **Owner's instruction**

### Monitoring Information



#### AUXILIARY SOLAR THERMAL PUMP

This icon indicates that auxiliary solar thermal pump is active.

**NOTE** : As installation of auxiliary solar thermal pump is not compulsory but recommendation according to field condition, this icon can be seen although no auxiliary solar thermal pump is installed.

#### Water Pump

This icon indicates that the water pump inside the indoor unit is active.

#### Sanitary Water Tank heater

This icon indicates that sanitary water tank electric heater which is located inside sanitary water tank is active.


The icon is not used when sanitary water tank is not installed.

#### **Electric Heater STEP ONE**

#### Electric Heater STEP TWO

These icons indicate that the backup electric heater which is located inside the indoor unit is operating.

### Monitoring Information



NO FUNCTION

Child Lock

#### Outdoor

This icon indicates that the outdoor unit is active.

#### Disinfection

This icon indicates disinfecting operation is ongoing in sanitary water tank.

#### Maintain lowest temperature


The purpose of this mode is maintaining the temperature to prevent damage by freezing of water pipe.

#### Defrosting

This icon indicates that the defrost mode is active.


In space heating operation or sanitary water tank heating operation, freezing of the outdoor heat exchanger may be occured due to low outdoor temperature and humidity. If this risk occurs, the product goes into defrost operation. It reverses the cycle and takes heat from the indoor system to prevent freezing of the outdoor system. This mode is automatically operating.

### Monitoring Information



### Mode Change

Turn on the product and select operation mode.




#### **Operation Mode**


- Cooling Operation The product yields cool water to use in under floor cooling or FCU cooling.
- Heating Operation The product yields hot water to use in under floor heating or FCU heating.
- Weather dependent Heating Operation In this mode, heating setpoint is automatically determined by pre-defined temperature profile. For more detail, please

refer description on Function Code 24 and 25.

### Selecting Target Temperature

You can set the proper temperature each mode.





#### 

. Decrease 1°C or 2°F per one time pressing


Increase 1°C or 2°F per one time pressing


- We can change the temperature range of each mode on installation setting mode. Please refer Function Code 11 to 15.
- Room Temperature setting is available when Remote Room Air Sensor (sold separately) is installed. Please refer Function Code 03.

#### 12 Air-to-Water Heat Pump Owner's Manual

### Cooling Mode

In this mode, cooling operation is activated to achieve the temperature set point.





## \* Note

: Decrease 1°C or 2°F per one time pressing


Increase 1°C or 2°F per one time pressing


We can change the temperature range of each mode on installation setting mode.

Please refer function code from 11 to 15.

### Heating Mode

In this mode, heating operation is activated to achieve the temperature set point.








### Weather-dependent Operation

This mode is only applied to heating.

In order to save energy and to give highest comfort, setting temperature will follow outside temperature. If outdoor temperature decreases, heating capacity for the house will increase automatically in order to keep same room temperature. All parameters will be set by installer during start-up procedure and will be adapted to the site characteristic.









#### Owner's instruction

### View Temperature






(unit:°C)

Temperature	Temperature Range Displayed as	
	below 11	Lo
Air	11 ~ 39	actual temperature
	above 39	Hi
	below 0	Lo
Water	0 ~ 92	actual temperature
	above 92	Hi

### Sanitary Water Heating Operation

OFERATION            값:            GSTALIE         PLOT WATER           않:            않:            값:            값:            값:            값:            :            :            :            :            :            :            :	
Remote Controller	
	STT CLEAR VEW TIMP
	<b>1</b> -




#### <Note>

- This function is not used when the sanitary water tank is not installed.
- If you want to know more information, refer function code [15, 26~29] on installation information section

### Silent Mode Operation

Silent mode operation is that the outdoor unit works at reduced capacity so that the noise produced by the outdoor unit drops.




D This implies that the indoor heating and cooling capacity will also drop. Beware of this when a certain level of heating or cooling is required indoors.


D Silent mode operation may not work while the product is proceeding higher priority operation such as defrost operation, anti-freezing operation, and etc. ((When this mode is not operated by the priority order, ONLY display SILENT).)

ENGLISH

### Child Lock


This function is to prevent children or other people from using controller.






### Error code display


When the error is occurred on indoor unit, the error code will be displayed on control panel.



### Setting Current Time


You can set current time.






#### <Note>


The current time have set as 12:00 initially.





### Programming : Setting Simple Reservation


You can easily turn-on reservation.(ONLY enable when unit is stand-by.)



Press programming button to enter the Programming mode. (the segment flashing)			
Ex) Setting Simple Reservation time as '3' hours.			
Press up, down button to adjust the reservation time.			
3 If you finish the setting, press setting/cancel button to complete programming.			
<b>4</b> Press exit button to exit or system will automatically release without any input after 25 seconds.			

### Programming : Setting Sleep Reservation

You can easily turn-off(sleep) reservation.(ONLY enable when unit is operating.)





1	Press programming button to enter the Programming mode. Repeat pressing button to select [sleep reservation]. (the segment flashing)
	RESERVATION SLEEP
	Ex) Setting Simple Reservation time as '3' hours.
2	Press up, down button to adjust the reservation time.
	RESERVATION SLEEP
3	If you finish the setting, press setting/cancel button to complete programming.
	Grenation ** Status Generation
4	Press exit button to exit or system will automatically release without any input after 25 seconds.


1


### Programming : Setting ON Reservation

This function is able to turn-on after a setting time.













### Programming : Setting OFF Reservation

This function is able to turn-off after a setting time.












### Programming : Weekly Reservation


The weekly reservation is active after setting current time.





1	Press programming button to enter the Programming mode. Repeat pressing button to select [Weekly reservation]. (The segment will be flashed)
l t	
	Ex) Setting one action as below. - Day : TUE - ON Time : 11:30 AM - OFF Time : 12:30 PM
	Press left, right button to adjust the current day.
	SUN MON TUE WED THU FRI SAT
3	Press up, down button to adjust the action number.
4	Press right button to move to 'Hour' Part on ON Time section. (The 'Hour' segment will be flashed)
	RESERVATION SUN MON THE KEY THU FR SAT












### Programming : Holiday Reservation

This function is to automatically stop the machine working on some days.



## **Using Thermostat**

The term "thermostat", which is widely used in this chapter, is a kind of 3rd party accessory. LG Electronics does not supply thermostat and it should be supplied 3rd party manufacturers. Room thermostat can be used for easy and convenience control. To utilize thermostat more efficiently and correctly, this chapter presents information about using thermostat.

### 

- 1. NEVER USE 230V AC Thermostat and 24V AC Thermostat at the same time. If used together, it causes short-circuit and yields power cut-off by circuit breaker.
- 2. Some electro-mechanical type thermostat has internal delay time to protect compressor. In that case, mode change can takes time more than user's expectation. Please read thermostat manual carefully if the product does not response quickly.
- 3. Setting temperature range by thermostat can be different with that of the product. The heating or cooling set temperature should be chosen within the setting temperature range of the product.

### Supported Thermostat Specification

Туре	Power	Operating Mode	Supported
Mechanical	230 V AC	Heating Only (3)	Yes
(1)		Heating / Cooling (4)	Yes
	24 V AC	Heating Only (3)	Yes
		Heating / Cooling (4)	Yes
Electrical	230 V AC	Heating Only (3)	Yes
(2)		Heating / Cooling (4)	Yes
	24 V AC	Heating Only (3)	Yes
		Heating / Cooling (4)	Yes

#### **THERMAN** supports following thermostats.

- (1) : There is no electric circuit inside the thermostat and electric power supply to the thermostat is not required.
- (2) : Electric circuit such as display, LED, buzzer, etc is included in the thermostat and electric power supply is required.
- (3) : Thermostat generates 'Heating ON or Heating OFF' signal according to user's heating target temperature.
- (4) : Thermostat generates both 'Heating ON or Heating OFF' and 'Cooling ON or Cooling OFF' signal according to user's heating and cooling target temperature.

### Installing and Wiring Thermostat

Please refer 'Conditions if Accessories are Installed' of Chapter 4 and 'Thermostat' of Chapter 7 of **THERMAV**. Installation Manual.

### How to use Thermostat

To find how to turn on and off, how to set target temperature, how to change operating mode, etc, please refer thermostat operating manual provided by thermostat manufacturer.

### **Operating Thermostat with Control Panel**

#### • Following features are permitted when thermostat is installed :

- SET TEMP button
- VIEW TEMP button
- 🕞 🛆 Temperature adjust button (\*)
- Sanitary water heating Enable / Disable
- Silent operation On / Off
- (\*) : Adjusted temperature is only used to control electric heater on / off condition. The product does not turn on / off according to the setting temperature at the control panel. It turns on / off according to the thermostat signal.

#### • Following features are NOT permitted when thermostat is installed :

- Operating mode (cooling/ heating/ weather-dependent) selection
- Time scheduling
- Operation On / Off

### **Emergency Operation**

#### Definition of terms

- Trouble : a problem which can stop system operation, and can be resumed temporally under limited operation without certificated professional's assist.
- Error : problem which can stop system operation, and can be resumed ONLY after certificated professional's check.
- Emergency mode : temporary heating operation while system met Trouble.

#### Objective of introducing 'Trouble'

- Not like airconditioning product, Air-to-Water heat pump is generally operation in whole winter season without any system stopping.
- If system found some problem, which is not critical to system operating for yielding heating energy, the system can temporarily continue in emergency mode operation with end user's decision.

#### Classified Trouble

- Trouble is classified two levels according to the seriousness of the problem : Slight Trouble and Heavy trouble
- Slight Trouble : a problem is found inside the indoor unit. In most case, this trouble is concerned with sensor problems. The outdoor unit is operating under emergency mode operation condition which is configured by DIP switch No. 4 of the indoor unit PCB.
- Heavy trouble : a problem is found inside the outdoor unit. As the outdoor unit has problem, the emergency mode operation is performed by electric heater located in the indoor unit.
- Option Trouble : a problem is found for option operation such as water tank heating. In this trouble, the troubled option is assumed as if it is not installed at the system.

#### • Emergency operation level

- When system met trouble, it stops operation and wait for user's decision : Calling service center or starting emergency operation.
- To start emergency operation, user simply push ON / OFF button once more.
- Two different levels are prepared for emergency operation : High temperature cycle and low temperature cycle.
- In emergency operation mode, user can not adjust target temperature.

	DIP Switch	Target Leaving Water Temperature	Target Room Air Temperature	Target Sanitary Water Temperature
High temperature cycle	OFF	55°C	30 °C	70 °C
Low temperature cycle	ON	30 °C	25 °C	70 °C

#### • Following features are permitted in emergency operation :

- Operation On/Off
- VIEW TEMP button(\*)
- < 🛆 Temperature adjust button (\*)
- Sanitary water heating Enable / Disable
- (\*) : Temperature measured by failed sensor is displayed as '- -'.

(\*) : Adjusted temperature is only used to control electric heater on / off condition.

The product does not turn on / off according to the setting temperature at the control panel. It turns on / off according to the thermostat signal.

#### • Following features are NOT permitted in emergency operation :

- Operating mode (cooling/ heating/ weather-dependent) selection
- E Time scheduling
- SET TEMP button
- 😥 Silent operation On / Off

#### Duplicated trouble : Option trouble with Slight or Heavy trouble

- If option trouble is occurred with slight (or heavy) trouble at the same time, the system puts higher priority to slight (or heavy) trouble and operates as if slight (or heavy) trouble is occurred.
- Therefore, sometimes sanitary water heating can be impossible in emergency operation mode. When sanitary water is not warming up while emergency operation, please check if sanitary water sensor and related wiring are all Ok.

#### • Emergency operation is not automatically restarted after main electricity power is reset.

- In normal condition, the product operating information is restored and automatically restarted after main electricity power is reset.
- But in emergency operation, automatic re-start is prohibited to protect the product.
- Therefore, user must restart the product after power reset when emergency operation has been running.

## **Maintenance and Service**

### Maintenance activities

In order to ensure optimal availability of the unit, a number of checks and inspections on the unit and the field wiring have to be carried out at regular intervals, preferably yearly. This maintenance should be carried out by your local agreed technician.

### When the unit is not going....

#### 

- If the product is not used for long time, we strongly recommen NOT TO SWITCH OFF THE POWER SUPPLY to the product.
- If power is not supplied, some special product-protecting actions (such as water pump anti-locking) will not performed.

#### Call the service immediately in the following situations

- 1. Anything abnormal such as burning smell, loud noise etc. happen. Stop the unit and turn the breaker off. Never try to repair by yourself or restart the system in such cases.
- 2. Main power cord is too hot or damaged.
- 3. Error code is generated by self diagnosis.
- 4. Water leaks from indoor unit.
- 5. Any switch, breaker (safety, earth) or fuse fails to work properly

User must carry routine checkup & cleaning to avoid unit's poor performance. In case of special situation, the job must be carried out by the only service person.

### Troubleshooting Tips! Save time and money!

Check the following points before requesting repairs or service.... If the malfunction persist, please contact your dealer.

Case	Explanation	
AWHP does not operate.	Have you made a mistake in timer operation?	
	Has the fuse blown or has the circuit breaker been tripped?	
The room has a peculiar odor.	• Check that this is not a damp smell exuded by the walls, carpet, furniture or cloth items in the room.	
AWHP does not operate for	This is the protector of the mechanism.	
about 3 minutes when restart.	Wait about three minutes and operation will begin.	
Does not cool or heat effectively.	• The room may have been very hot when the AWHP was first turned on. Allow time for it to cool down.	
	Has the setting temperature been set incorrectly?	
The unit operation is noisy.	<ul> <li>Refrigerant flow sound</li> <li>While the system is being started or stopping, sound from the refrigerant flow may be heard.</li> </ul>	
	<ul> <li>Sound for the indoor unit heat exchanger</li> <li>During the cooling operation, a sound may be heard from the indoor unit heat exchanger due to water freezing or melting.</li> </ul>	
	Water noise     During starting or stopping of the unit, noise can appear in water piping	
	During defrost     Noise can appear in unit due to defrosting of water.	
Steam is raised in outdoor unit.	<ul> <li>Steam from outdoor heat exchanger</li> <li>During defrosting operation, ice on the outdoor heat exchanger is melted, resulting in making steam.</li> </ul>	
Control panel display is faint, or no display at all.	Has the circuit breaker been tripped?	

## **Disposal Requirements**

Dismantling of the unit, treatment of the refrigerant, of oil and of other parts must be done in accordance with relevant local and national legislation.



Your product is marked with this symbol. This means that electrical and electronic products shall not be mixed with unsorted household waste.

Do not try to dismantle the system yourself: the dismantling of the system, treatment of the refrigerant, of oil and other parts must be done by a qualified installer is accordance with relevant local and national legislation.

Units must be treated at a specialized treatment facility for re-use, recycling and recovery. By ensuring this product is disposed off correctly, you will help to prevent potential negative consequences for the environment and human health. Please contact the installer or local authority for more information.

