

INSTALLATION MANUAL AIR CONDITIONER

TYPE : WALL MOUNTED
Original instruction

ENGLISH



Copyright © 2017 - 2019 LG Electronics Inc. All Rights Reserved.
MFL70500701
Rev.00_052119



IMPORTANT SAFETY INSTRUCTIONS

READ ALL INSTRUCTIONS BEFORE USING THE APPLIANCE.

Always comply with the following precautions to avoid dangerous situations and ensure peak performance of your product.

⚠ WARNING

It can result in serious injury or death when the directions are ignored.

⚠ CAUTION

It can result in minor injury or product damage when the directions are ignored.

⚠ WARNING

- Installation or repairs made by unqualified persons can result in hazards to you and others.
- Air conditioner Shall be installed in accordance with national wiring regulations.
- If the supply cord is damaged, it must be replaced by

the manufacturer, its service agent or similarly qualified persons in order to avoid a hazard.

- The information contained in the manual is intended for use by a qualified service technician familiar with safety procedures and equipped with the proper tools and test instruments.
- Failure to carefully read and follow all instructions in this manual can result in equipment malfunction, property damage, personal injury and/or death.
- When the power cord is to be replaced, replacement work shall be performed by authorized personnel only using only genuine replacement parts.
- Air conditioner shall be disconnected from its power source during service and when replacing parts.

Installation

- Always perform grounding.
 - Otherwise, it may cause electrical shock.
- Don't use a power cord, a plug or a loose socket which is damaged.
 - Otherwise, it may cause a fire or electrical shock.
- For installation of the product, always contact the service center or a professional installation agency.
 - Otherwise, it may cause a fire, electrical shock, explosion or injury.
- Securely attach the electrical part cover to the indoor unit and the service panel to the outdoor unit.
 - If the electrical part cover of the indoor unit and the service panel of the outdoor unit are not attached securely, it could result in a fire or electric shock due to dust, water, etc.

- Always install an air leakage breaker and a dedicated switching board.
 - No installation may cause a fire and electrical shock.
- Do not keep or use flammable gases or combustibles near the air conditioner.
 - Otherwise, it may cause a fire or the failure of product.
- Ensure that an installation frame of the outdoor unit is not damaged due to use for a long time.
 - It may cause injury or an accident.
- Do not disassemble or repair the product randomly.
 - It will cause a fire or electrical shock.
- Do not install the product at a place that there is concern of falling down.
 - Otherwise, it may result in personal injury.
- Use caution when unpacking and installing.
 - Sharp edges may cause injury.
- Thickness of copper pipes used are as shown "Flaring work" Table.
 - Never use copper pipes thinner than that in the table even when it is available on the market
- Do not use copper pipes having a collapsed.

- Otherwise, the expansion valve or capillary tube may become blocked with contaminants.
- For R410A model, use piping, flare nut and tools which is specified for R410A refrigerant.
 - Using of (R22) piping, flare nut and tools may cause abnormally high pressure in the refrigerant cycle (piping), and possibly result in explosion and injury.
- It is desirable that the amount of residual oil less than 40 mg/10 m.
- If air enters the refrigerant system, an excessively high pressure results, causing equipment damage or injury.
- Always check for gas (refrigerant) leakage after installation or repair of product. Low refrigerant levels may cause failure of product.
- Ensure that you grab the chassis when you lift the unit.
 - If you lift the unit with the panel held, it may result in serious injury or product failure.
- Do not turn on the breaker or power under condition that front panel, cabinet, top cover, control box cover are removed or opened. Otherwise, it may cause fire, electric shock, explosion or death.
- Make the connections securely so that the outside force of the cable may not be applied to the terminals.
 - Inadequate connection and fastening may generate heat and cause a fire.
- After pump down, power must be turned off before removing the pipe.
 - When operating this product without connecting the pipe, there will be high pressure inside the compressor due to the entry of air, possibly causing explosion or injury.

Operation

- Do not share the outlet with other appliances.
 - It will cause an electric shock or a fire due to heat generation.
- Do not use the damaged power cord.
 - Otherwise, it may cause a fire or electrical shock.
- Do not modify or extend the power cable.
 - Scratches or peeling insulation on the power cables may result in fire or electric shock, and should be replaced.
- Take care so that the power cord may not be pulled during operation.
 - Otherwise, it may cause a fire or electrical shock.
- Unplug the unit if strange sounds, smell, or smoke comes from it.
 - Otherwise, it may cause electrical shock or a fire.
- Keep the flames away.
 - Otherwise, it may cause a fire.
- Take the power plug out if necessary, holding the head of the plug and do not touch it with wet hands.
 - Otherwise, it may cause a fire or electrical shock.
- Do not use the power cord near the heating tools.
 - Otherwise, it may cause a fire and electrical shock.
- Do not open the suction inlet of the indoor/outdoor unit during operation.
 - Otherwise, it may electrical shock and failure.
- Do not allow water to run into electrical parts.
 - Otherwise, it may cause the failure of machine or electrical shock.
- Hold the plug by the head when taking it out.
 - It may cause electric shock and damage.

- Never touch the metal parts of the unit when removing the filter.
 - They are sharp and may cause injury.
- Do not step on the indoor/outdoor unit and do not put anything on it.
 - It may cause an injury through dropping of the unit or falling down.
- Do not place a heavy object on the power cord.
 - Otherwise, it may cause a fire or electrical shock.
- When the product is submerged into water, always contact the service center.
 - Otherwise, it may cause a fire or electrical shock.
- Take care so that children may not step on the outdoor unit.
 - Otherwise, children may be seriously injured due to falling down.

⚠ CAUTION

Installation

- Install the drain hose to ensure that drain can be securely done.
 - Otherwise, it may cause water leakage.
- Install the product so that the noise or hot wind from the outdoor unit may not cause any damage to the neighbors.
 - Otherwise, it may cause dispute with the neighbors.
- Always inspect gas leakage after the installation and repair of product.
 - Otherwise, it may cause the failure of product.
- Install at places where it can endure the weight and vibration/noise of the outdoor unit.

- Keep level parallel in installing the product.
 - Otherwise, it may cause vibration or water leakage.
- Air conditioners should not be installed in areas where corrosive gases, such as acid or alkaline gas, are produced
- Do not install the product where it could be exposed to sea wind (salty wind) directly.
 - It can result corrosion on the product. Corrosion, particularly on the condenser and evaporator fins, could cause product malfunction or inefficient performance.
- If outdoor unit is installed close to the sea-side, it should avoid direct exposure to the sea wind.
 - Otherwise it needs additional anticorrosion treatment on the heat exchanger.
- Always install an earth leakage circuit breaker in a wet or moist area.
- The earth wire should be longer than the common wires.
- As for the method of wiring, be guided by the circuit diagram posted on the inside of control cover.
- The screw which fasten the wiring in the casing of electrical fittings are liable to come loose from vibrations to which the unit is subjected during the course of transportation. Check them and make sure that they are all tightly fastened.
- Confirm that electrical capacity is sufficient.
- The means for disconnection from a power supply shall be incorporated in the fixed wiring and have an air gap contact separation of at least 3 mm in each active (phase) conductors.

- Open the terminal cover block before connecting the indoor side wire.
- The indoor unit can be dropped from the wall, when the indoor unit is not screwed correct position on the install plate.
- To avoid nitrogen entering the refrigerant system in a liquid state, the top of the cylinder must be higher than its bottom when you pressurize the system.
- Inert gas (nitrogen) should be used when you check plumbing leaks, cleaning or repairs of pipes etc.
 - If you are using combustible gases including oxygen, product may have the risk of fires and explosions.

Operation


- Avoid excessive cooling and perform ventilation sometimes.
 - Otherwise, it may do harm to your health.
- Use a soft cloth to clean. Do not use wax, thinner, or a strong detergent.
 - The appearance of the air conditioner may deteriorate, change color, or develop surface flaws.
- Do not use an appliance for special purposes such as preserving animals vegetables, precision machine, or art articles.
 - Otherwise, it may damage your properties.
- Do not place obstacles around the flow inlet or outlet.
 - Otherwise, it may cause the failure of appliance or an accident.

INTRODUCTION

Symbols used in this Manual


- ⚠ This symbol alerts you to hazards that may cause harm to the air conditioner.
- ! This symbol indicates special notes.

Features



* The feature can be changed according to type of model.

INSTALLATION MAP



* The feature can be changed according to a type of model.

* Work to the vinyl tape should up from below.

! NOTE

* You should purchase the installation parts. (It can be changed according to market)

INSTALLATION PARTS

Name	Quantity	Shape
Installation plate	1 EA	
Type "A" screw	5 EA	
Type "B" screw	2 EA	
Type "C" screw	2 EA	
Remote control holder	1 EA	
Cloth tape	1 EA	
Connector	1EA (18,24 kBTu/h)	

Screws for fixing panels are attached to decoration panel.
When indoor unit (18,24 kBTu/h) is connected to the Multi Outdoor unit, use the connector.


INSTALLATION TOOLS

Figure	Name	Figure	Name
	Screw driver		Multi-meter
	Electric drill		Hexagonal wrench
	Measuring tape, Knife		Ammeter
	Hole core drill		Gas-leak detector
	Spanner		Thermometer, Level
	Torque wrench		Flaring tool set

INSTALLATION

Select the best Location

- There should not be any heat or steam near the unit.
- Select a place where there are no obstacles around of the unit.
- Make sure that condensation drainage can be conveniently routed away.
- Do not install near a doorway.
- Ensure that the interval between a wall and the left or right of the unit is more than 100 mm. The unit should be installed as high as possible on the wall, allowing a minimum of 200 mm from ceiling.
- Use a metal detector to locate studs to prevent unnecessary damage to the wall.




* The feature can be changed according to type of model.

! NOTE

The gap between the indoor unit and ceiling is needed more than 200 mm for disassemble the air filter.

Outdoor unit


- If an awning is built over the unit to prevent the direct sunlight or rain exposure, make sure that heat radiation from the condenser is not restricted.
- Ensure that the space around the back and sides is more than 300 mm. The space in front of the unit should be more than 700 mm of space.
- Do not place animals and plants in the path of the warm air.
- Take the weight of the air conditioner into account and select a place where noise and vibration are minimum.
- Select a place where the warm air and noise from the air conditioner do not disturb neighbors.



* The feature can be changed according to type of model.


Burrs removal

- Completely remove all burrs from the cut cross section of pipe/tube.
- While removing burrs put the end of the copper tube/pipe in a downward direction while removing burrs location is also changed in order to avoid dropping burrs into the tubing.



Putting nut on

- Remove flare nuts attached to indoor and outdoor unit, then put them on pipe/tube having completed burr removal. (not possible to put them on after finishing flare work)




Flaring work

- Firmly hold copper pipe in a bar with the dimension shown in below table.
- Carry out flaring work with the flaring tool.

Pipe diameter inch (mm)	A inch (mm)	Wing nut type	Clutch type
1/4 (6.35)	0.04-0.05 (1.1-1.3)		
3/8 (9.52)	0.06-0.07 (1.5-1.7)		
1/2 (12.7)	0.06-0.07 (1.6-1.8)		
5/8 (15.88)	0.06-0.07 (1.6-1.8)		
3/4 (19.05)	0.07-0.08 (1.9-2.1)		

Drill a Hole in the Wall


- Drill the piping hole with a 665 mm hole core drill. Drill the piping hole at either the right or the left with the hole slightly slanted to the outdoor side.



Flaring Work


Main cause for gas leakage is due to defect of flaring work. Carry out correct flaring work in the following procedure.

- Use the piping kit accessory or the pipes purchased locally.
- Measure the distance between the indoor and the outdoor unit.
- Cut the pipes a little longer than measured distance.
- Cut the cable 1.5 m longer than the pipe length.



Check

- Compare the flared work with the figure by.
- If a flared section is defective, cut it off and do flaring work again.




Connecting the Piping

- Put the cover at the bottom of the indoor unit. Pull the cable (1) - (2).
- Remove the cover from the indoor unit.





- 3 Pull back the tubing holder.
- 4 Remove pipe port cover and positioning the tubing



* The feature can be changed according to type of model.

Assembly of chassis cover

- 1 Insert 4 hooks of the chassis cover into gap of the chassis certainly.




* The feature can be changed according to type of model.

! NOTE

To protect the chassis cover bended, assembly chassis cover correctly.



- 3 Pull back the tubing holder.
- 4 Remove pipe port cover and positioning the tubing



* The feature can be changed according to type of model.

Assembly of chassis cover

- 1 Insert 4 hooks of the chassis cover into gap of the chassis certainly.




* The feature can be changed according to type of model.

! NOTE

Installation Information. For right piping. Follow the instruction above.


Installation of Indoor Unit

- 1 Hook the indoor unit onto the upper portion of the installation plate (engage the three hooks at the top of the indoor unit with the upper edge of the installation plate) Ensure that the hooks are properly seated on the installation plate by moving it left and right.




Check

- 1 Pull the cover at the bottom of the indoor unit. Pull the cable (1) - (2).
- 2 Remove the cover from the indoor unit.




Left side piping

- 1 Insert the connecting cable through the bottom side of indoor unit and connect the cable (You can see detail contents in "Connecting the cables" section)




Left side piping

- 1 Hook the indoor unit onto the upper portion of the installation plate (engage the three hooks at the top of the indoor unit with the upper edge of the installation plate) Ensure that the hooks are properly seated on the installation plate by moving it left and right.




Right side piping

- 1 Pull the cover at the bottom of the indoor unit. Pull the cable (1) - (2).
- 2 Remove the cover from the indoor unit.




Right side piping

- 1 Insert the connecting cable through the bottom side of indoor unit and connect the cable (You can see detail contents in "Connecting the cables" section)



Connecting the installation pipe and drain hose to the indoor unit.


- Align the center of the pipes and sufficiently tighten the flare nut by hand.




* When indoor unit (6.6 kW) is connected to the Multi Outdoor unit, use the connector.

- Tighten the flare nut with a wrench.

Outside Diameter					
mm	inch	kgf·cm	N·m		
Ø6.35	1/4	180~250	17.6~24.5		
Ø9.52	3/8	340~420	33.3~41.2		
Ø12.7	1/2	550~660	53.9~64.7		
Ø15.88	5/8	630~820	61.7~80.4		




- When needed to extend the drain hose of indoor unit, assembly the drain pipe as shown on the drawing.








Wrap the insulation material around the connecting portion.

- Overlap the connection pipe insulation material and the indoor unit pipe insulation material. Bind them together with vinyl tape so that there may be no gap.




- Set the tubing cutting line upward. Wrap the area which accommodates the rear piping housing section with vinyl tape.



* Wrap the piping of the indoor unit that are visible from the outside with vinyl tape.

Use round pressure terminals for connections to the power terminal block.





CAUTION

- According to the confirmation of the above conditions, prepare the wiring as follows.
 - Never fail to have an individual power circuit specifically for the air conditioner. As for the method of wiring, be guided by the circuit diagram posted on the inside of control cover.
 - The screw which fasten the wiring in the casing of electrical fittings are liable to come loose from vibrations to which the unit is subjected during the course of transportation. Check them and make sure that they are all tightly fastened. (If they are loose, it could cause burn-out of the wires.)
 - Specification of power source.
 - Confirm that electrical capacity is sufficient.
 - See that the starting voltage is maintained at more than 90 percent of the rated voltage marked on the name plate.
 - Confirm that the cable thickness is as specified in the power source specification. (Particularly note the relation between cable length and thickness.)
 - Always install an earth leakage circuit breaker in a wet or moist area.
 - The following would be caused by voltage drop.
 - Vibration of a magnetic switch, which will damage the contact point, fuse breaking, disturbance of the normal function of the overload.
 - The means for disconnection from a power supply shall be incorporated in the fixed wiring and have an air gap contact separation of at least 3 mm in each active phase conductors.
 - Open the terminal cover block before connecting the indoor side wire.

Finishing the indoor unit installation

- Mount the tubing holder in the original position.
- Ensure that the hooks are properly seated on the installation plate by moving it left and right.
- Press the lower left and right sides of the unit against the installation plate until the hooks engage into their slots (clicking sound).
- Finish the assembly by screwing the unit to the installation plate by using two pieces of type "C" screws. And assemble a chassis cover.




* The feature can be changed according to type of model.

CAUTION
The indoor unit can be dropped from the wall, the indoor unit is not screwed correct position on the install plate. To avoid the gap between the indoor unit and wall, screw the indoor unit to the install plate correctly.

Forming the Piping


Form the piping by wrapping the connecting portion of the indoor unit with insulation material and secure it with two kinds of vinyl tapes.

- If you want to connect an additional drain hose, the end of the drain outlet should be routed above the ground. Secure the drain hose appropriately.



In cases where the outdoor unit is installed below the indoor unit perform the following.

- 1 Tape the piping, drain hose and connecting cable from down to up.
- 2 Secure the tapped piping along the exterior wall using saddle or equivalent.



* The feature can be changed according to type of model.

CAUTION
The indoor unit can be dropped from the wall, the indoor unit is not screwed correct position on the install plate. To avoid the gap between the indoor unit and wall, screw the indoor unit to the install plate correctly.

* The feature can be changed according to type of model.

In cases where the Outdoor unit is installed above the Indoor unit perform the following.

- 1 Tape the piping and connecting cable from down to up.
- 2 Secure the taped piping along the exterior wall. Form a trap to prevent water entering the room.
- 3 Fix the piping onto the wall using saddle or equivalent.



* The feature can be changed according to type of model.


Air Purging
The air and moisture remaining in the refrigerant system have undesirable effects as indicated below.

- 1 Pressure in the system rises.
- 2 Operating current rises.
- 3 Cooling/heating efficiency drops.
- 4 Moisture in the refrigerant circuit may freeze and block capillary tubing.
- 5 Water may lead to corrosion of parts in the refrigeration system.

Therefore, after evacuating the system, take a leak test for the piping and tubing between the indoor and outdoor unit.

Air purging with vacuum pump

- 1 Preparation
 - Check that each tubelboth liquid and gas side tubes) between the indoor and outdoor units have been properly connected and all wiring for the test run has been completed. Remove the service valve caps from both the gas and the liquid side on the outdoor unit. Note that both the liquid and the gas side service valves on the outdoor unit are kept closed at this stage.




* The feature can be changed according to type of model.

Required time for evacuation when 30 gal/h vacuum pump is used		
If tubing length is less than 10 m (33 ft)	If tubing length is longer than 10 m (33 ft)	
10 min. or more	15 min. or more	

- When the desired vacuum is reached, close the knob of the 3-way valve and stop the vacuum pump.

Finishing the Job

- With a service valve wrench, turn the valve of liquid side counter-clockwise to fully open the valve.
- Turn the valve of gas side counter-clockwise to fully open the valve.
- Loosen the charge hose connected to the gas side service port slightly to release the pressure, then remove the hose.
- Replace the flare nut and its bonnet on the gas side service port and fasten the flare nut securely with an adjustable wrench. This process is very important to prevent leakage from the system.
- Replace the valve caps at both gas and liquid side service valves and fasten them tight. This completes air purging with a vacuum pump.
- Replace the pipe cover to the outdoor unit by one screw. Now the air conditioner is ready for test run.



* The feature can be changed according to type of model.

Pressure gauge
Open Close

Vacuum pump


Connecting the Cables

Indoor unit

Connect the cable to the indoor unit by connecting the wires to the terminals on the control board individually according to the outdoor unit connection. (Ensure that the color of the wires of the outdoor unit and the terminal No. are the same as those of the indoor unit.)

Insert the connecting cable through the bottom side of indoor unit and connect the cable.

- (1) Open the Decor
- (2) Unscrew the screw of C/Bax
- (3) Slide up the Metal Plate Cover
- (4) Connect the connecting cable
- (5) After complete connect the cables, should assemble the Metal Plate Cover by screw.




* The feature can be changed according to type of model.

CAUTION

- The circuit diagram is a subject to change without notice.
- The earth wire should be longer than the common wires.
- When installing, refer to the circuit diagram on the chassis cover.
- Connect the wires firmly so that they may not be pulled out easily.
- Connect the wires according to color codes, referring to the wiring diagram.

NOTE

The power cord connected to unit should be selected according to the following national wiring regulations. The supply cords of parts of appliances for outdoor use shall not be lighter than polychloroprene sheathed flexible cord (code designation 60245 IEC 57, H05RN-F)



NOMINAL CROSS SECTIONAL AREA	Grade
9.12, 18.24 kBut/h	0.75




The power connecting cable with indoor and outdoor unit should be selected according to the following national wiring regulations. The supply cords of parts of appliances for outdoor use shall not be lighter than polychloroprene sheathed flexible cord (code designation 60245 IEC 57, H05RN-F)

- Connect the wires to the terminals on the control board individually.
- Secure the cable onto the control board with the cord clamp.

Checking the Drainage

To check the drainage.


- 1 Pour a glass of water on the evaporator.
- 2 Ensure the water flows through the drain hose of the indoor unit without any leakage and goes out the drain exit.




* The feature can be changed according to type of model.

Drain piping

- 1 The drain hose should point downward for easy drain flow.



- 2 Do not make drain piping like the following.





* The feature can be changed according to type of model.

Installing drain piping of the outdoor unit

Depending on installation site, it may be required to install drain plug for drainage (Supplied with the unit). In cold areas, do not use a drain hose with the outdoor unit. Otherwise, drain water may freeze, impairing the heating performance.

- 1 See the figure below for installation of the drain plug.
 - A Drain nipple
 - B Drain cap
 - C Drain washer
- 2 Connect a field supplied vinyl hose to the drain nipple (A). If the hose is too long and hangs down, fix it carefully to prevent kinks.



* The feature can be changed according to type of model.

- 2 Leak test
 - Connect the manifold valvewith pressure gauges) and dry nitrogen gas cylinder to this service port with charge hoses.

NOTE
Be sure to use a manifold valve for air purging. If it is not available, use a stop valve for this purpose. The knob of the 3-way valve must always be kept close.

- Pressurize the system to maximum 17.6 kg/cm²G (R22 model) or 28.1 kg/cm²G (R410A model) with dry nitrogen gas and close the cylinder valve when the gauge reading reaches 17.6 kg/cm²G (R22 model) or 28.1 kg/cm²G (R410A model). Next step is leak test with liquid soap.

CAUTION



To avoid nitrogen entering the refrigerant system in a liquid state, the top of the cylinder must be higher than its bottom when you pressurize the system. Usually, the cylinder is used in a vertical standing position.

WARNING

There is a risk of fire and explosion. Inert gas (nitrogen) should be used when you check plumbing leaks, cleaning or repairs of pipes etc. If you are using combustible gases including oxygen, product may have the risk of fires and explosions.

- Do a leak test of all joints of the tubing(both indoor and outdoor) and both gas and liquid side service valves. Bubbles indicate a leak. Be sure to wipe off the soap with a clean cloth.

- After the system is found to be free of leaks, relieve the nitrogen pressure by loosening the charge hose connector at the nitrogen cylinder. When the system pressure is reduced to normal, disconnect the hose from the cylinder.



Soap water method

- Remove the caps from the 2-way and 3-way valves.
- Remove the service-port cap from the 3-way valve.
- Apply a soap water or a liquid neutral detergent on the indoor unit connection or outdoor unit connections by a soft brush to check for leakage of the connecting points of the piping.
- If bubbles come out, the pipes have leakage

Evacuation



- Connect the charge hose end described in the preceding steps to the vacuum pump to evacuate the tubing and indoor unit. Confirm the "Lo" knob of the pressure Gauge is open. Then, run the vacuum pump. The operation time for evacuation varies with tubing length and capacity of the pump. The following table shows the time required for evacuation.

Test Running

- Check that all tubing and wiring are properly connected.
- Check that the gas and liquid side service valves are fully open.

Prepare remote controller


- 1 Remove the battery cover by pulling it according to the arrow direction.
- 2 Insert new batteries making sure that the (+) and (-) of battery are installed correctly.
- 3 Reattach the cover by pushing it back into position.



NOTE

- Use 2 AAA(1.5 V) batteries. Do not use rechargeable batteries.
- Remove the batteries from the remote controller if the system is not used for a long time.

Test operation





- If you press and hold the On/Off button for 3 ~ 5 seconds instead of 6 seconds, the unit will switch to the test operation.

- In the test operation, the unit blows out strong air for cooling for 18 minutes and then returns to the factory default settings.

Settlement of outdoor unit

- 1 Fix the outdoor unit with a bolt and nut (ø10 mm) tightly and horizontally on a concrete or rigid mount.
- 2 When installing on the wall, roof or rooftop, anchor the mounting base securely with a nail or wire assuming the influence of wind and earthquake.
- 3 If the vibration of the unit is transmitted to the pipe, secure the unit with an anti-vibration rubber.




Evaluation of the performance

Operate the unit for 15~20 minutes, then check the system refrigerant charge:

- 1 Measure the pressure of the gas side service valve.
- 2 Measure the air temperature from inlet and outlet of air conditioner.
- 3 Ensure the difference between the inlet and outlet temperature is more than 8 °C.
- 4 For reference, the gas side pressure at optimum condition is shown on table (cooling)

The air conditioner is now ready to use.



* The feature can be changed according to type of model.

Refrigerant	Outside ambient TEMP.	The pressure of the gas side service valve.
R22	35 °C (96 °F)	4~5 kg/cm ² G (56.8~71.0 P.S.I.G.)
R410A	35 °C (96 °F)	8.5~9.5 kg/cm ² G (120~135 P.S.I.G.)

Installation guide at the seaside

CAUTION

- Air conditioners should not be installed in areas where corrosive gases, such as acid or alkaline gas, are produced.
- Do not install the product where it could be exposed to sea wind (salty wind) directly. It can result corrosion on the product. Corrosion, particularly on the condenser and evaporator fins, could cause product malfunction or inefficient performance.
- If outdoor unit is installed close to the seaside, it should avoid direct exposure to the sea wind. Otherwise it needs additional anticorrosion treatment on the heat exchanger.

Windbreak

Sea wind

- It should be strong enough like concrete to prevent the sea wind from the sea.

- The height and width should be more than 150 % of the outdoor unit.

- Keep more than 70 cm of space between outdoor unit and the windbreak for easy air flow.

Select a well-drained place.

- If you can't meet above guide line in the seaside installation, please contact LG Electronics for the additional anticorrosion treatment.



- Periodic (more than once/year) cleaning of the dust or salt particles stuck on the heat exchanger by using water

* Do not use seawater when you clean up the heat exchanger.

Sea wind

Sea wind

In case of installing the outdoor unit on the sea side, setup a windbreak to prevent sea wind.



- It should be strong enough like concrete to prevent the sea wind from the sea.

- The height and width should be more than 150 % of the outdoor unit.

- Keep more than 70 cm of space between outdoor unit and the windbreak for easy air flow.

Select a well-drained place.

- If you can't meet above guide line in the seaside installation, please contact LG Electronics for the additional anticorrosion treatment.

- Periodic (more than once/year) cleaning of the dust or salt particles stuck on the heat exchanger by using water

* Do not use seawater when you clean up the heat exchanger.

Sea wind

Sea wind

Manual the decor, air filter Assembly & Disassembly

Disassemble the decor

- 1 Turn off the power and unplug the power cord.
- 2 Pull the decor at the bottom of the indoor unit.




3 Remove the decor from the indoor unit.

Assemble the decor

- 1 Turn off the power and unplug the power cord.
- 2 Insert 3 or 4 hooks of the decor into gap of the indoor unit certainly.



3 Push the nooks to assemble the decor.



CAUTION

The air filter can be broken when it is bended.

Disassemble the air filter


- 1 Turn off the power and unplug the power cord.
- 2 Hold the knob of the air filter. Lift it up slightly.




3 Hold the knob of the air filter, lift it up slightly and remove it from the unit.

Assemble the air filter

- 1 Turn off the power and unplug the power cord.
- 2 Insert the hooks of the air filter into the front grille.



3 Push down hooks to assemble the air filter.



4 Check side of the front grille for the air filter assembled correctly.

NOTE

If the air filter is not assembled correctly, Dust and other substance come into the indoor unit. If look at the indoor unit from higher than it, can assemble the air filter easily.

Precautions about installation in regions with extreme snowfall and cold temperatures

To ensure the outdoor unit operates properly, certain measures are required in locations where there is a possibility of heavy snowfall or severe wind chill or cold.

- 1 Prepare for severe winter wind chills and heavy snowfall, even in areas of the country where these are unusual phenomena.
- 2 Position the outdoor unit so that its airflow fans are not buried by direct, heavy snowfall. If snow piles up and blocks the airflow, the system may malfunction.
- 3 Remove any snow that has accumulated 100 mm or more on the top of the outdoor unit.
- 4 Place the outdoor unit on a raised platform at least 500 mm higher than the aver- age annual snowfall for the area. If the frame width is wider than the outdoor unit, snow may accumulate.
- 5 Install a snow protection hood.
- 6 To prevent snow and heavy rain from entering the outdoor unit, install the suction and dis- charge ducts facing away from direct winds.
- 7 Additionally, the following conditions should be taken into consideration when the unit operates in defrost mode:
 - If the outdoor unit is installed in a highly humid environment (near an ocean, lake, etc.), en- sure that the site is well-ventilated and has a lot of natural light. (Example: Install on a rooftop.)

TIPS FOR SAVING ENERGY

Here are some tips that will help you minimize the power consumption when you use the air conditioner. You can use your air conditioner more efficiently by referring to the instructions below:

- Do not cool excessively indoors. This